

Realift RPC 5.00.0 Release Notes

Realift sRPCx70 5.00.0 is a major feature release, first available in June 2021. The Realift RPC now runs only on the SCADAPack 474.

Application and Firmware Versions

The Pump Controller version is 5.00.0 build 453

The HMI version is 5.00.0 build 89

New Feature(s) (5.00.0)

These new features were added:

- The Realift RPC can now control concurrently 2 pumps using a single SCADAPack 474 RTU
- The Realift RPC I/O assignment can now be made using the Magelis HMI interface
- The Realift RPC documentation and Magelis HMI projects are now available through Schneider Electric Exchange
- The Realift RPC Magelis HMI projects are now available with support for the HMIGTO2310 and HMISTU855
- The Realift RPC now includes a well simulator for demonstration, training, and testing

Fixed Issue (5.00.0)

This issue is fixed:

- **Feature Affected:** Erroneous display of the “No Active License or No Active Application” alarm banner

Issue: If power is cycled to the sRPC, an alarm banner indicating “No Active License or No Active Application” may be displayed on the HMI. This alarm appears because the HMI can start, and check for the pump controller application before the pump controller application has begun.

Fix: The system now does not display this banner before the application has started.

Engineering Reference: [56152](#)